



Chambers Mechanical LLC

P.O. Box 116
Shrewsbury, PA 17361
(717) 993-0800

July 22, 2023

To whom it may concern,

This letter is to inform you that we resolved an issue with the A/C system we found their was a minor leak in the service valves. We replaced the schrader valve stems, pressure tested & recharged the system. We also replaced the air filter. The system is from 2008. We had installed the Honeywell thermostats, zone dampers, & zone board. We also installed the condensation pump. Those parts have a 5-year part warranty. There is no other warranty for the equipment. This is a heat pump system with backup electric heat. The manuals for the equipment and controls are provided. Everything had been tested, and currently in a working state.

Sincerely,
Chambers Mechanical