



MICHAEL BARLOW WELL DRILLING & SERVICE, INC.
 522 Underwood Lane Bel Air, Maryland 21014
 (410) 838-6910 Fax (410) 838-3582

WELL YIELD REPORT

Date Test Completed:	November 16, 2021		
Well Depth:	305	feet	
Customer	Krauss Realty	Permit #	BA-88-1744
Road	11308 John Carroll Road	Subdivision	
City	Owings Mills	Section	
State	MD	Lot #	

Time	Water Level feet	Time to Fill 1-gallon bucket seconds	G.P.M.
9:30 AM	31	5	12.00
9:45 AM	104	22	2.73
10:00 AM	108	30	2.00
10:15 AM	108	30	2.00
10:30 AM	108	30	2.00
10:45 AM	108	30	2.00
11:00 AM	108	30	2.00
11:15 AM	108	30	2.00
11:30 AM	108	30	2.00
11:45 AM	108	30	2.00
12:00 PM	108	30	2.00
12:15 PM	108	30	2.00
12:30 PM	108	30	2.00
12:45 PM	108	30	2.00
1:00 PM	108	30	2.00
1:15 PM	108	30	2.00
1:30 PM	108	30	2.00
1:45 PM	108	30	2.00
2:00 PM	108	30	2.00
2:15 PM	108	30	2.00
2:30 PM	108	30	2.00
2:45 PM	108	30	2.00
3:00 PM	108	30	2.00
3:15 PM	108	30	2.00
3:30 PM	108	30	2.00
3:45 PM	108	30	2.00
4:00 PM	108	30	2.00

This yield test report is for informational purposes only. Please note the yield may increase or decrease over time and the GPM indicated above is not a guarantee.