

Nancy Harthun
12801 Harford Rd.
Fork, Md.

Re: Oil tank Removal

18 Feb 2017

Ms. Harthun:

RCFS, Inc. is pleased to inform you that the removal of one, UST has been completed (10 Feb 2017) by a MDE Certified Tank Technician (#0082). Complying with MDE / NFPA regs as applicable to the requirements. The UST was a 1000-gallon single wall storage tank, with NO visible signs of leakage and or damage to tank surface. Soil sample from 2-3 ft below tank bottom showed NO visible signs and strong odors of fuel oil contaminates.

MDE Inspections were not conducted at time of tank removal.

Baltimore County Env. Office did make there site visit / inspection.

The UST (1280 lbs) has been rendered useless and recycled through the local scrap yard, Harford County recyclers, see disposal receipt #109238.

The excavation was backfilled with virgin soils and sand, from local supplier. Seed and straw applied to finish graded areas.

Further actions are NOT expected.

Payment has been received in order of check.

Thank you,

Thomas W. Over

President, RCFS, Inc.

MDE Certified Technician # 2015-0082