Page 1 of 1

Date 11-16-24

Baltimore ~~Frederick~~ County

County Well No. _____

Reviewed By _____

FIELD DATA SHEET
HYDROGEOLOGIC AREA (3) WELL YIELD TEST

Maryland Well Permit No. BA-23-0205 Owner or Applicant SHARIA ROLES

Location of Property (road) 12923 FALLS RD COCKEYSVILLE

Subdivision _____ Lot ____ Block ____ Plat ____ Sec. ____

Well Driller PERRY HARLOW

Depth of Well 620FD

Distance of Measuring Point (M.P.) above ground 2FD

Static Water Level (S.W.L.) below M.P. 91

I. High Rate Pumping — reservoir drawdown

Time pump started 9:00 AM Pumping rate 15GPM

Total time 20 MIN to reach pumping water level 350 ft. below M.P.

II. Recovery pump test data - observations to be recorded every 15 minutes.

TIME (CHRON.)	WATER LEVEL Below M.P.	PUMPING RATE Time to fill 1 gal. bucket	FLOW METER READING (if used)	CALCULATED FLOW (gallons per min.)
9:20	350FD	12 SEC		5 GPM
9:35	350 "	12 "		5 "
9:50	350 "	12 "		5 "
10:05	350 "	12 "		5 "
10:20	350 "	12 "		5 "
10:35	350 "	12 "		5 "
10:50	350 "	12 "		5 "
11:05	350 "	12 "		5 "
11:20	350 "	12 "		5 "
11:35	350 "	12 "		5 "
11:50	350 "	12 "		5 "
12:05	350 "	12 "		5 "
12:20	350 "	12 : "		5 "